

West Sussex County Council
Development Control
County Hall Tower Street
Chichester
West Sussex
PO19 1RH

Our ref: HA/2024/125712/01-L01

Your ref: WSCC/007/24

Date: 28 February 2024

Dear Sir/Madam

INSTALLATION OF INTEGRATED CONSTRUCTED WETLAND (ICW) AND ASSOCIATED INFRASTRUCTURE AT LAND ADJACENT TO STAPLEFIELD WASTEWATER TREATMENT WORKS.

STAPLEFIELD WASTEWATER TREATMENT WORKS, CUCKFIELD ROAD, STAPLEFIELD, WEST SUSSEX, RH17 6ES

Thank you for the consultation on the above application, please quote our reference on all correspondence.

Environment Agency Position

The Environment Agency have no objections to this application as proposed.

Environmental Permit - Advice to Applicant

The Environmental Permitting (England and Wales) Regulations 2016 require a permit or exemption to be obtained for any activities which will take place:

- on or within 8 metres of a main river (16 metres if tidal).

For further guidance please visit <https://www.gov.uk/guidance/flood-risk-activities-environmental-permits> or contact our National Customer Contact Centre on 03708 506 506 (Monday to Friday, 8am to 6pm) or by emailing enquiries@environment-agency.gov.uk.

The applicant should not assume that a permit will automatically be forthcoming once planning permission has been granted, and we advise them to consult with us at the earliest opportunity.

Environment Agency
Canal Walk, ROMSEY, Hampshire, SO51 7LP.
Customer services line: 03708 506 506
www.gov.uk/environment-agency

Cont/d..

Yours faithfully

Miss Suz Greenwood
Planning Advisor, Environment Agency

Direct dial 02084745098

Direct fax

Direct e-mail suz.greenwood@environment-agency.gov.uk