

**From:** [FRS Water and Access](#)  
**To:** [PL Planning Applications](#)  
**Subject:** Planning consultation - WSCC/016/24 The Haulage Yard, Dial Post, West Sussex, RH13 8NY  
**Date:** 27 June 2024 15:48:08  
**Attachments:** [image003.png](#)  
[image004.png](#)  
[image005.png](#)

---

FAO: Chris Bartlett

Dear Chris,

Having viewed the plans for the planning application no WSCC/016/24 for the proposed extension to existing haulage and plant maintenance depot to enable an inert waste transfer and recycling facility (Variation of Condition 2 for Proposed Installation of Wash Plant Equipment), the nearest fire hydrant for the supply of water for firefighting is 250-metres away, 160-metres further than the 90-metre distance required for a commercial premises. If an alternative supply of water for firefighting is to be considered it will need to conform with the details identified in Approved Document-B (AD-B) Volume 2: B5 section 16 and agreed with West Sussex Fire & Rescue Service.

Regards

Ian



**Ian Stocks**

Water & Access Manager - Protection

**West Sussex Fire & Rescue Service**

**Office** 0330 222 4499 **Mobile** 07921 291051

**Web** [www.westsussex.gov.uk/fire](http://www.westsussex.gov.uk/fire)

**Email** [frs.waterandaccess@westsussex.gov.uk](mailto:frs.waterandaccess@westsussex.gov.uk)

Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

**My pronouns are he/him/his** 🏳️‍🌈

[Click here to find out why we use pronouns in our signatures](#)

