



Alison Woodfield/PL/WSCC

12/09/2012 09:30

To PL Planning Applications/WSCC@wsc

cc

bcc

Subject Fw: Wood Barn Farm - Planning Application
WSCC/052/12/WC

----- Forwarded by Alison Woodfield/PL/WSCC on 12/09/2012 09:30 -----



David Boarer/FB/WSCC

07/09/2012 13:34

To Alison Woodfield/PL/WSCC@WSCC

cc David McMahon/FB/WSCC@WSCC, Rob

Mapley/FB/WSCC@WSCC, Mark

Swanton/FB/WSCC@WSCC, Fiona

Hargreaves/FB/WSCC@WSCC

Subject Fw: Wood Barn Farm - Planning Application
WSCC/052/12/WC

Alison

The development appears to be remote from the main road and if it is approved we will need to see site of the access routes, any provisions of water for firefighting and risk to surrounding area. The local fire station is Billingshurst which is a one pump station so what onsite fire fighting provisions are being installed due to the nature of the processes. Also at a later stage we will need notification if there is to be any flaring so that fire calls are not inadvertently received.

David

[David Boarer](#) | Water and Access Manager, [West Sussex County Council](#)
Location: West Sussex Fire and Rescue Service, Power Place, 23 Terminus Road, Chichester, PO19 8TX
Internal: 83667 | External: 01243 813667 | E-mail: david.boarer@westsussex.gov.uk

Think sustainably. Do you have to print? Can you double side? Do you need colour?