

From: Oliver Benson <Oliver.Benson@midsussex.gov.uk>
Sent: 01 June 2021 10:27
To: Chris Bartlett <chris.bartlett@westsussex.gov.uk>
Subject: RE: Evergreen Farm - WSCC/004/20

Hi Chris,

Thank you for making me aware of this.

I've had a look over the Ground Investigation report by Geo-Environmental, and based on the information submitted, I would condition 1, previously recommended by myself has been met.

I would still recommend that discovery strategy is left in placers, and that we required a verification report prior to any occupation of the site.

I would caveat again, that I do not have the knowledge or expertise to comment on the detailed design of the venting system specified or the geotechnical information relating to cohesion and stability analysis.

Happy to discuss.

Many thanks,

Oliver

Oliver Benson BSc (Hons), MCIEH
Contaminated Land and Environmental Protection Officer
Environmental Health
Room 3, The West Wing
Mid Sussex District Council
Oaklands Road
Haywards Heath
RH16 1SS
Tel: 01444 477 059
Mobile: 07889 741 575
Email: oliver.benson@midsussex.gov.uk

