


From: Ian Stocks <ian.stocks@westsussex.gov.uk> **On Behalf Of** FRS Water and Access
Sent: 04 May 2021 11:01
To: PL Planning Applications <planning.applications@westsussex.gov.uk>
Subject: Planning consultation - WSCC/011/21 Ford Circular Technology Park, Ford Road, Ford, BN18 0XL

FAO: James Neave

Dear James,

Having viewed the information provided for planning application no. WSCC/011/21 we are aware there are currently two private fire hydrants on the site (Shown on our mapping attached).



Information is required regarding the current private hydrants, are they both being retained and in their current location?

If the hydrants are not being retained additional fire hydrants will be required to comply with the requirements of Approved Document – B (AD-B) Volume 2 2019 edition: B5 section 16.

Regards

Ian

Ian Stocks – Water and Access Manager
Water and Access Office
West Sussex Fire and Rescue Service [West Sussex County Council](http://www.westsussex.gov.uk)
Location: Bognor Fire Station, West Meads Drive, Bognor, PO21 5TB
Phone: 0330 222 3117 | E-mail: frs.waterandaccess@westsussex.gov.uk