



West Sussex Fire & Rescue Service
Arun District Office
Bognor Regis Fire Station
West Meads Drive
West Sussex PO21 5TB

Telephone No: (01243) 837785
Fax No: (01243) 837787

TO:	JAMES NEAVE
FROM:	WEST SUSSEX FIRE & RESCUE SERVICE
DATE:	13/12/05
COMMENTS OR MESSAGE:	Please find copy of report regarding Lichsey Offield KIND REGARDS CHRIS BISHOP
THIS FAX CONSISTS OF THIS SHEET and PAGES	

County Fire Officer

Martin Burrell
QFSM, MIFireE, DMS



Arun District Office

West Sussex Fire & Rescue Service
Westmeads Drive Bognor Regis
West Sussex PO21 5TB

Telephone: (01243) 837785
Fax: (01243) 837787
e-mail: arundistrictoffice@westsussex.gov.uk

Direct dial
(01243) 837785

Our reference
8C/3492

Your reference

11th November 2005

Mr J. Neave
West Sussex County Council
County Planning
Tower Street
Chichester
West Sussex
PO19 1RL

Re: Lidsey Oilfield, Lidsey, Bognor Regis, West Sussex, PO22 9PF

Dear Mr Neave,

With reference to the planning application, application number BN/05 submitted to West Sussex Fire & Rescue Service.

It is the opinion of West Sussex Fire & Rescue Service that the proposals are unsatisfactory. The following items need to be addressed:-

- 1) There are insufficient water supplies for fire fighting purposes.
- 2) The access road for fire appliances is insufficient in width this needs to be rectified in accordance with Approved Document B B5 Section 17.8 and Table 21.
- 3) A turning circle is required for fire appliances within the site.
- 4) The on site water tank is to be fitted with 45mm instantaneous couplings for Fire Service access.

Should you wish to discuss the contents of this correspondence, please do not hesitate to contact me on the above telephone number.

Chris Bishop
Arun District Commander

Copy

West Sussex Fire & Rescue Service – West Sussex County Council
"..... Making West Sussex Safer"



Awarded for excellence